

建 筑			暖 通		
结 构			给 排 水		
电 气			工 艺		
通 讯			自 控		

配电箱编号	配电箱展开图	备注
ALS	<div><div><div>Pe=5.0KW Cosφ=0.85 Pjs=5.0KW Ijs=8.9A</div><div>三相电表 10(40)A</div><div>CH2-63 C25/3</div></div><div><div>L1 CH1-63 C16/1</div><div>L2 CH1-63 C16/1</div><div>L3 CH1L-63 C20/2</div><div>L1 CH1L-63 D20/2</div><div>L2 CH1L-63 C20/2</div><div>L3 CH1L-63 C20/2</div></div><div><div>WL1 NHBV-3x2.5-SC20-WC/CC</div><div>WL2 BV-3x2.5-PC20-CC</div><div>WL3 BV-3x4.0-PC25-FC</div><div>WL4 BV-3x4.0-PC25-FC</div><div>WL5</div><div>WL6</div></div><div><div>疏散照明</div><div>照明</div><div>插座</div><div>柜式空调插座</div><div>备用</div><div>备用</div></div></div>	商业照明配电箱 (500X400X160) 嵌墙暗装 底边距地1.8M 漏电断路器动作 电流30mA动作 时间t<0.1S
AS	<div><div><div>Pe=10.0KW Kx=0.8 Cosφ=0.85 Pjs=10.0KW Ijs=14.3A</div><div>三相电表 10(40)A</div><div>CH1G-100/4P</div></div><div><div>CM2-63L 4300,IN=4.0 In=300mA tn=0.4s</div><div>CM1-63L 3300,IN=32</div><div>CM1-63L 3300,IN=32</div></div><div><div>SCB:T08/100 -C14/4P</div><div>SPD为级 SPD:VA 150/3PN</div><div>WLS1</div><div>WLS2</div></div><div><div>ALS</div><div>ALS</div></div></div>	商业总进线箱 楼梯间嵌墙暗装 底边距地1.6M
APZ	<div><div><div>Pe=39.0KW Kx=0.9 Cosφ=0.85 Pjs=35.1KW Ijs=62.7A</div><div>三相电表 2.5(10)A</div><div>CH1G-100/4P</div></div><div><div>CM2-125L 4300,IN=80 In=300mA tn=0.4s</div><div>CM1-63 C16/1</div><div>CM1-100L 3300,IN=63</div></div><div><div>SCB:T08/100 -C14/4P</div><div>SPD为级 SPD:VA 150/3PN</div><div>WLS1</div><div>WLS2</div></div><div><div>ALS</div><div>ALS</div></div></div>	住宅总进线箱 嵌墙暗装 底边距地1.6m